

CITY OF LOS ANGELES

CALIFORNIA



ERIC GARCETTI
MAYOR

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

RAYMOND S. CHAN, C.E., S.E.
GENERAL MANAGER

FRANK BUSH
EXECUTIVE OFFICER

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

E. FELICIA BRANNON
VICE-PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
JAVIER NUNEZ

Tree Island Industries Ltd.
3933 Boundary Road
Richmond, BC, CANADA V6V 1T8

Attn: Olga Drigola
(604) 524-3744 x 4279

RESEARCH REPORT: RR 25895
(CSI # 06 05 23.13)

BASED UPON ICC EVALUATION SERVICE
REPORT NO. ESR- 1768

REEVALUATION DUE
DATE: April 1, 2016
Issued Date: October 1, 2015
Code: 2014 LABC

GENERAL APPROVAL – Clerical Modification - Mechanically and Manually Driven Nails.

DETAILS

The above assemblies and/or products are approved when in compliance with the description, use, identification and findings of Evaluation Report No. ESR-1768, reissued August 1, 2014, Revised June 2015 of the ICC Evaluation Service, Incorporated. The report, in its entirety, is attached and made part of this general approval.

The parts of Evaluation Report No. ESR-1768 marked by an asterisk, are deleted by the Los Angeles City Building Department from this approval.

The approval is subject to the following conditions:

1. Installation of the nails shall be per the manufacturer's instructions and ES Report No. ESR-1768, copies which shall be available at the job site.
2. The material fastened shall be investigated for compliance with accepted design criteria and code requirements.
3. Except as specified in section 5.5 of the attached ICC-ES report, the nails shall not be used in chemically treated wood such as pressure-preservative or fire retardant treated wood and shall not be used in exterior or exposed conditions.

RR 25895
Page 1 of 2

Tree Island Industries Ltd
RE: Mechanically and Manually Driven Nails

4. Lateral strength nominal values for the nails tabulated in Table 4 of the ESR-1768 require minimum 1" side member thickness.
5. All nails shall have smooth, ring (annularly threaded) or screw (helically threaded) shanks and concentric round heads.

DISCUSSION

Clerical Modification is to update the report to the 2014 LABC.

The report is in compliance with the 2014 Los Angeles City Building Code.

The approval was based on data in accordance with ICC-ES Acceptance Criteria for Nails and Spikes (AC116), dated June 2014 (editorially revised April 2015).

This general approval will remain effective provided the Evaluation Report is maintained valid and unrevised with the issuing organization. Any revisions to the report must be submitted to this Department, with appropriate fee, for review in order to continue the approval of the revised report.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.

QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-202-9812
Fax- 213-202-9943

QN
RR25895/MSWord2010
R09/25/2015
2303.6

Attachments: ICC-ES Evaluation Report No. ESR-1768 (5-Pages).

ICC-ES Evaluation Report**ESR-1768***

Reissued August 2014

This report is subject to renewal August 2016.

www.icc-es.org | (800) 423-6587 | (562) 699-0543

A Subsidiary of the International Code Council®

**DIVISION: 06 00 00—WOODS, PLASTICS AND
COMPOSITES**
Section: 06 05 23.13—Nails**REPORT HOLDER:****TREE ISLAND INDUSTRIES, LTD.**
3933 BOUNDARY ROAD
RICHMOND, BRITISH COLUMBIA V6V 1T8
CANADA
(604) 524-3744
www.treeisland.com**EVALUATION SUBJECT:****PNEUMATICALLY, MECHANICALLY AND MANUALLY
DRIVEN ROUND-HEAD NAILS, ROOFING NAILS AND
NAILS FOR APPLICATION OF GYPSUM BOARD****ADDITIONAL LISTEE:****HALSTEEL—TREE ISLAND WIRE (U.S.A.), INC.**
4190 EAST SANTA ANA
ONTARIO, CALIFORNIA 91761
(909) 355-3552**1.0 EVALUATION SCOPE****Compliance with the following codes:**

- * ■ ~~2015~~, 2012 and 2009 *International Building Code*® (IBC)
- * ■ ~~2015~~, 2012 and 2009 *International Residential Code*® (IRC)

Properties evaluated:

- Bending yield strength.
- Compliance with material requirements and tolerances of ASTM F1667.
- Compliance with prescriptive requirements of the IBC and IRC.
- Use in diaphragms, shear walls and braced walls.
- Compliance with ASTM C514.

2.0 USES

The nails described in this report are used for engineered and prescriptive structural connections between wood members, for attachment of roofing materials to wood sheathing, and for attachment of gypsum board products to wood framing.

3.0 DESCRIPTION**3.1 General:**

The nails are formed from plain steel wire of Grades 1006 through 1030; or stainless steel Type 304 or 316. The nails have smooth, ring (annularly threaded) or screw (helically threaded) shanks and concentric round heads.

3.2 Structural Nails:

See Table 1 for dimensions and additional information for hand-driven nails recognized for use in structural applications, including specified bending yield strength and available finishes. See Table 2 for dimensions and additional information for collated, gun-driven nails recognized for use in structural applications. Dimensional tolerances conform to ASTM F1667.

Some of the sizes of the nails listed in Tables 1 and 2 are available as True Spec brand nails. The True Spec system is intended to allow the shank size and length of a nail to be determined after it is driven, by referring to the nail color and/or the code stamped on the head of the nail. For non-galvanized nails, the length is identified by the paint color on the nail head and the shank diameter is defined by a number. For galvanized nails, the length is identified by a letter and the shank diameter is defined by a number or letter. Non-galvanized nails intended for use with framing connectors (hardware) also have an 'H' on the head. Ring and screw shank nails are identified by an 'r' stamped on the head. See Table 3 for applicable colors and codes.

3.3 Roofing Nails:

Roofing nails have a nominal shank diameter of 11 gage [0.124 inch (3.1 mm)] and a flat round head with a nominal diameter of 0.437 inch (11.1 mm). The nails are available in lengths ranging from $\frac{5}{8}$ inch to 3 inches (15.9 to 76 mm) and are either hot-dipped galvanized or electro-galvanized. Nail length must comply with the applicable requirements in Section 1507 of the IBC or Section R905 of the IRC. Dimensional tolerances conform to ASTM F1667.

3.4 Nails for Application of Gypsum Board:

The nails used for attachment of gypsum boards to wood framing members have a nominal shank diameter of 13 gage [0.095 inch (2.4 mm)], $\frac{5}{16}$ -inch-diameter (7.9 mm) cupped heads and lengths ranging from $1\frac{1}{4}$ to $1\frac{7}{8}$ inches (32 to 48 mm). The nails comply with the material, ductility, withdrawal resistance and dimensional tolerances of ASTM C514, and are manufactured with zinc-phosphate etched surface treatment.

*Revised June 2015

4.0 DESIGN AND INSTALLATION

4.1 Design:

4.1.1 Engineered Structural Connections: The structural nails listed in Tables 1 and 2 comply with the requirements of IBC Section 2303.6 and may be used in connections designed in accordance with the ANSI/AWC National Design Specification (NDS) for Wood Construction, using the specified bending yield strengths and nominal nail diameters shown in the tables. Reference lateral and withdrawal values for select connections are shown in Table 4. These reference design values must be adjusted by all applicable factors in the NDS.

4.1.2 Engineered Diaphragms and Shear Walls: The structural nails listed in Table 5 comply with the requirements of IBC Section 2303.6 and head area requirements defined in the ICC-ES Acceptance Criteria for Nails (AC116) and are equivalent to the code-prescribed nails listed in Table 5 for use in engineered diaphragms and shear walls in accordance with the AWC Special Design Provisions for Wind and Seismic (SDPWS), which is referenced in the IBC.

4.1.3 Prescriptive Framing Connections: The structural nails listed in Tables 1 and 2 comply with the requirements of IBC Section 2303.6 and may be used in framing connections where the applicable nail type and size is prescribed in ~~2015 IBC Table 2304.10.1~~ (2012 and 2009 IBC Table 2304.9.1) or IRC Table R602.3(1), as applicable.

4.1.4 Prescriptive Sheathing Attachment: The structural nails listed in Table 5 comply with the requirements of IBC Section 2303.6 and head area requirements of AC116, and are equivalent to the code-prescribed nails listed in Table 5 for attachment of sheathing to wood framing in accordance with ~~2015 IBC Table 2304.10.1~~ (2012 and 2009 IBC Table 2304.9.1) or IRC Table R602.3(1), as applicable.

4.2 Installation:

4.2.1 Structural Nails: Edge distances, end distances, and spacings must be sufficient to prevent splitting of the wood, and must be in accordance with ~~2015 NDS Section 12.1.5~~ (2012 NDS Section 11.1.6 for the 2012 IBC; 2005 NDS Section 11.1.5 for the 2009 IBC).

4.2.2 Roofing Nail: Roofing nails must be installed in accordance with IBC Chapter 15 or IRC Chapter 9. When used in roofing applications, the roofing nails must be hot-dipped galvanized in accordance with ASTM A153, Class D.

4.2.3 Nails for Installation of Gypsum Board: Nails used to attach gypsum board to wood framing members must be installed in accordance with ASTM C840, GA-216, or IRC Section 702.3. The nails may be used for fire-resistance-rated construction where wallboard nails are prescribed in IBC Tables 721.1(2) and 721.1(3). With proper application, the nail heads are deformed to a level surface.

5.0 CONDITIONS OF USE

The nails described in this report comply with the codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1** Use of the nails must comply with this report and the applicable code.
- 5.2** When required by the code official, calculations demonstrating that the applied loads are less than the design values specified by this report must be submitted for approval. Calculations must be prepared by a registered design professional where required by the statutes of the jurisdiction in which the project is to be constructed.
- 5.3** Use of roofing nails must be limited to installation of roof covering materials and other non-structural materials in accordance with IBC Chapter 15 or IRC Chapter 9.
- 5.4** Nails evaluated for compliance with ASTM C514 must be limited to installation of gypsum board materials in accordance with IBC Section 2508 or IRC Section R702.3.
- 5.5** Tree Island stainless steel nails and nails with a hot-dip galvanized coating may be used with pressure-preservative-treated wood and fire-retardant-treated wood in accordance with ~~2015 IBC Section 2304.10.5~~ (2012 and 2009 IBC Section 2304.9.5) and IRC Section 317.3.
- 5.6** Use of the nails with a bright finish in chemically-treated wood, such as pressure-, preservative-, or fire-retardant-treated wood; or in exterior or exposed conditions, is not permitted.
- 5.7** Use of the electro-galvanized zinc or zinc-phosphate coated nails in chemically-treated wood, such as pressure-, preservative-, or fire-retardant-treated wood; or in exterior or exposed conditions is outside the scope of this report.

6.0 EVIDENCE SUBMITTED

- 6.1** Data in accordance with the ICC-ES Acceptance Criteria for Nails (AC116), dated June 2014 (editorially revised April 2015).
- 6.2** Reports of tests in accordance with ASTM C514.

7.0 IDENTIFICATION

Containers of nails must be identified with the company name (Tree Island Industries, Ltd., or Halsteel) and address; nail type and pennyweight and/or nail size [length and diameter (or gage for roofing and gypsum nails)]; the finish or coating, and the evaluation report number (ESR-1768). True Spec nails must also be identified as described in Section 3.2 and Table 3.

TABLE 1—HAND DRIVEN STRUCTURAL NAILS

NAIL TYPE	PENNYWEIGHT	NOMINAL SHANK DIAMETER (inch)	SPECIFIED BENDING YIELD STRENGTH Fyb (psi)	LENGTH (inches)	HEAD STYLE	NOMINAL HEAD DIAMETER (inch)	SHANK TYPE	FINISH ¹
Box	6d / 7d	0.099	100,000	2 / 2 ¹ / ₄	Flat Round	0.265	Smooth	Bright, VC, EG, Phos, HDG
	8d / 9d	0.113		2 ¹ / ₂ / 2 ³ / ₄		0.297		
	10d / 12d	0.128		3 to 3 ³ / ₄		0.312		
	16d	0.135	3 ¹ / ₂	0.344				
	20d / 30d	0.148	90,000	4 to 4 ¹ / ₂		0.375		
	40d	0.162		5		0.406		
Casing	6d / 7d	0.099	100,000	2 / 2 ¹ / ₄	Countersunk, cupped	0.142	Smooth	HDG
	8d	0.113		2 ¹ / ₂		0.155		
	10d / 12d	0.131		3 / 3 ¹ / ₄		0.170		
	16d	0.135		3 ¹ / ₂		0.177		
Common	4d / 5d	0.099	100,000	1 ¹ / ₂ / 1 ³ / ₄	Flat Round	0.250	Smooth Ring	Bright, VC, HDG
	6d / 7d	0.113		2 / 2 ¹ / ₄		0.265		
	8d / 9d	0.131		2 ¹ / ₂ / 2 ³ / ₄		0.281		
	10d / 12d	0.148	90,000	3 / 3 ¹ / ₄		0.312		
	16d	0.162		3 ¹ / ₂		0.344		
	20d	0.192		80,000		4		
Hardware	n/a	0.120	100,000	1 ¹ / ₄ to 1 ¹ / ₂	Round	0.297	Smooth Ring Screw	Bright, EG, HDG
		0.120		90,000		1 ¹ / ₂ , 2 ¹ / ₂		0.281
		0.131	1 ¹ / ₄ to 1 ¹ / ₂			0.312		Bright, EG, HDG
		0.148	2 ¹ / ₂			0.344		HDG
		0.162	80,000	2 ¹ / ₂		0.375		
Finishing	8d	0.099	100,000	2 ¹ / ₂	Brad	0.142	Smooth	Bright, HDG
	10d / 12d	0.113		3 / 3 ¹ / ₄		0.155		
	16d	0.120		3 ¹ / ₂		0.162		
	20d	0.135		4		0.177		
Sinker	7d	0.099	100,000	2 ¹ / ₈	Flat countersunk	0.250	Smooth	VC, Phos, HDG
	8d	0.113		2 ³ / ₈		0.266		
	10d	0.120		2 ⁷ / ₈		0.281		
	12d	0.135		3 ¹ / ₈		0.312		
	16d	0.148	90,000	3 ¹ / ₄		0.344		

For SI: 1 inch = 25.4 mm, 1 psi = 6.89 kPa.

¹Finish types:

- Bright = Non-galvanized
- VC = Vinyl-coated
- EG = Zinc-coated (Electro-galvanized)
- Phos = Zinc-phosphate coated
- HDG = Zinc-coated (Hot-dipped galvanized) complying with ASTM A153 Class D

TABLE 2—GUN DRIVEN STRUCTURAL NAILS

NOMINAL SHANK DIAMETER (inch)	SPECIFIED BENDING YIELD STRENGTH Fyb (psi)	RANGE OF LENGTHS (inch)	HEAD STYLE	NOMINAL HEAD DIAMETER (inch)	SHANK TYPE ¹	FINISH ²
0.113	100,000	1½ to 2½	Flat Round	0.275	S, R, Sc	Bright, EG, HDG
					S	SS
0.120		2 to 3¼		0.275	S, R, Sc	Bright, EG, HDG, HT
					S	SS
0.131		1½ to 3½		0.285	S, R, Sc	Bright, EG, HDG, HT
					S	SS
0.135		2¼ to 3½		0.285	S, R, Sc	Bright, EG, HDG, HT
0.148					S, R, Sc	Bright, EG, HDG, HT
0.162	90,000	1½ to 4	0.285	S	SS	
				S, R, Sc	Bright, EG, HDG, HT	
0.162	90,000	2½ to 5⅛	0.290	S, R, Sc	Bright, EG, HDG, HT	
				S	SS	

For SI: 1 inch = 25.4 mm, 1 psi = 6.89 kPa.

¹Shank types: S = smooth, R = ring, Sc = screw

²Finish types:

- Bright = Non-galvanized
- EG = Zinc-coated (Electro-galvanized)
- HDG = Zinc-coated (Hot-dipped galvanized) complying with ASTM A153 Class D
- HT = Heat Treated
- SS = Stainless Steel nails

TABLE 3—TRUE SPEC HEAD IDENTIFICATION SYSTEM LEGEND¹

DIAMETER INDICATOR		
Nominal Shank Diameter	Indicator for Smooth Shank and Screw Shank Nails, All Finishes	Indicator for Ring Shank Nails with HDG Finish
0.113	1	T
0.131	3	W
0.135	5	X
0.148	4	Y
0.162	6	Z
LENGTH INDICATOR		
Length (Inches)	Indicator for Non-Galvanized Nails	Indicator for HDG Nails
1½	Purple	A
2⅛	Pink	B
2¼	Brown	C
2⅜	Green	D
2½	Blue	E
3	White	F
3¼	Black	J
3½	Orange	K

For SI: 1 inch = 25.4 mm, 1 psi = 6.89 kPa.

¹Non-galvanized nails intended for use with framing connectors (hardware) also have an ‘H’ on the head. Ring and screw shank nails are identified by an ‘r’ stamped on the head.

TABLE 4—SINGLE FASTENER CONNECTIONS—REFERENCE DESIGN VALUES (LATERAL AND WITHDRAWAL)^{1,5}

NOMINAL NAIL SHANK DIAMETER (inch)	LATERAL STRENGTH VALUE (lbf) ²			WITHDRAWAL VALUE FOR SMOOTH NAILS (lbf per inch) ³		WITHDRAWAL VALUE FOR THREADED NAILS (lbf per inch) ^{3,4}	
	Minimum Side Member Thickness (inches)	Southern Pine SG = 0.55	Douglas Fir-Larch SG = 0.50	Southern Pine SG = 0.55	Douglas Fir-Larch SG = 0.50	Southern Pine SG = 0.55	Douglas Fir-Larch SG = 0.50
0.099	3/4	61	55	31	24	-	-
0.113	3/4	79	72	35	28	-	-
0.120	1	89	81	37	29	41	32
0.128	1	101	93	40	31		
0.131	1	106	97	41	32	-	-
0.135	1	113	103	42	33	46	36
0.148	1	128	118	46	36	50	40
0.162	1	154	141	50	40	-	-
0.192	1	183	159	59	47	-	-

For **SI**: 1 inch = 25.4 mm, 1 lbf = 4.45 N.

¹Tabulated nominal values must be multiplied by all applicable adjustment factors in accordance with the NDS.

²Tabulated lateral design values are for nails inserted in side grain with nail axis perpendicular to wood fibers; minimum nail penetration into the main member must equal 10 diameters.

³Tabulated nominal withdrawal values are for nails driven in the side grain of the main member, with the nail axis perpendicular to the wood fibers.

⁴For diameters other than those noted, withdrawal values must be the same as for the smooth nails.

⁵Reference: ~~NDS 2015 edition. Lateral strength—Table 12N. Withdrawal formula—Section 12.2.3.~~

TABLE 5—STRUCTURAL NAILS RECOGNIZED FOR USE IN ENGINEERED DIAPHRAGMS AND SHEAR WALLS AND PRESCRIPTIVE SHEATHING ATTACHMENTS

NAIL TYPE AND SIZE PRESCRIBED IN THE CODE	TREE ISLAND NAIL DESCRIPTION (RECOGNIZED EQUIVALENT)	
	Hand Driven (See Table 1)	Gun Driven (See Table 2)
6d common (2" x 0.113")	8d box; 6d and 7d common; 8d sinker	2 to 2 1/2" x 0.113"
8d common (2 1/2" x 0.131")	10d box; 8d and 9d common	2 1/2" to 3" x 0.131"
10d common (3" x 0.148")	10 and 12d common; 16d sinker	—

For **SI**: 1 inch = 25.4 mm.